

The manufacturer declares hereby, that all power supplies listed below, are in conformity with the provisions of the following European Directives:

**2004/108/EC** Electromagnetic Compatibility Directive  
**2006/95/EC** Low Voltage Directive

**QTD20.241** Output: 24-28VDC; 20-17,5A continuous / 25-21,4A for 4 s Input: 600VDC

The following standards were used to assess the products:

## **EN 61000-6-4:2001 Generic emission standard for industrial environments**

- EN 55011:1998 + A1:1999 + A2:2002 class A and EN 55022:2006 class A radio disturbance

Configuration: Power supply on table, resistance load,  
line length load/mains line: 1m horizontal and 0,8m vertical for radiated interference (30MHz-1GHz)

## **EN 61000-6-2:2005 Generic immunity standard for industrial environments**

(also meets the requirements of EN 61000-6-1:2001 for residential environments)

- IEC 61000-4-2 / EN 61000-4-2:1995 + A1:1998 + A2:2001 Electrostatic discharge test
- IEC 61000-4-3 / EN 61000-4-3:2003 Radiated, radio-frequency, electromagnetic field
- IEC 61000-4-4 / EN 61000-4-4 :2004 Electrical fast transient/ burst immunity test
- IEC 61000-4-5 / EN 61000-4-5 :2006 Surge immunity test
- IEC 61000-4-6 / EN 61000-4-6:1996 + A1:2001 Conducted disturbances, radio-frequency fields

## **EN 60950-1:2006**

### **Information technology equipment - Safety – Part 1: General requirements**

PULS GmbH  
Arabellastraße 15  
81925 Muenchen  
Germany

Muenchen, 22.08.2007

Bernhard Erdl , Managing Director

No. G 367 1